



Product certificate K24408/04

Issued 2019-08-01

Replaces K24408/03

Page 1 of 3

Injection moulded fittings of PVC with flange connections

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Van de Lande B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K17301 "Leidingsystemen van PVC voor transport van drinkwater en ruw water" dated 15-09-2017.

Ronald Karel
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

286180711

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company
Van de Lande B.V.
Lissenveld 1
4941 VK RAAMSDONKSVEER
The Netherlands
Tel +31 (0)162 516000
Fax +31 (0)162 521417
www.vandelande.com

Production locations
Raamsdonksveer
(The Netherlands)



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Injection moulded fittings of PVC with flange connections

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

General

Injection moulded fittings of PVC with flange connections according to evaluation guideline BRL-K17301 "Piping systems of PVC for the transport of drinking water and raw water".

Detailed specification

The dimensions and types as indicated in the table given below belong to this certificate. All types are provided with rubber sealing elements.

Types	Sizes d x d x d (in mm)	Code number
MMA-pieces	∅ 63 x 63 x 63	RRS013063
	∅ 63 x 90 x 63	RRS013065
	∅ 75 x 63 x 75	RRS013074
	∅ 75 x 75 x 75	RRS013075
	∅ 75 x 90 x 75	RRS013076
	∅ 90 x 63 x 90	RRS013088
	∅ 90 x 75 x 90	RRS013089
	∅ 90 x 90 x 90	RRS013090
	∅ 110 x 63 x 110	RRS013107
	∅ 110 x 75 x 110	RRS013108
	∅ 110 x 90 x 110	RRS013109
	∅ 110 x 110 x 110	RRS013110
	∅ 160 x 90 x 160	RRS013156
	∅ 160 x 110 x 160	RRS013157
	∅ 160 x 160 x 160	RRS013160
	∅ 200 x 90 x 200	RRS013195
	∅ 200 x 110 x 200	RRS013196
	∅ 200 x 160 x 200	RRS013199
∅ 225 x 90 x 225	RRS013219	
∅ 225 x 110 x 225	RRS013220	

Types	Sizes d x d (in mm)	Code number
E-pieces	∅ 63 x 63	RRS031063
	∅ 75 x 75	RRS031075
	∅ 90 x 90	RRS031090
	∅ 110 x 110	RRS031110
	∅ 160 x 160	RRS031160

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

Injection moulded fittings of PVC with flange connections

MARKING

The products are marked with the Kiwa-mark.



Place of the mark: on each coupler or fitting or on the packaging.

The realization of the mark is as follows:

- non-erasable;
- imprint.

Compulsory specifications:

The products are provided with at least the following markings:

- **KIWA**  or  which is allowed for small diameters after consultation with Kiwa;
- manufacturer's name/mark or registered trademark;
- the indication "PVC";
- the nominal pressure (PN);
- indication of the field of application;
- the nominal outside diameter of the connecting pipe in mm;
- production period.

In case desired, the production period may be provided on the packaging. It is preferred to provide it on the couplers/fittings.

APPLICATION AND USE

The products are intended to be applied for the making of joints in drinking water pipes of unplasticized PVC.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Van de Lande B.V.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.